

LYTTON REFINERY SOURCE EMISSIONS MONITORING DATA for SULFUR DIOXIDE (SO₂)

			Last Hour Readings (SO ₂ in g/s)			
Source	Source Description	Fuel source	Current Reading	- 0.25 Hr	- 0.5 Hr	- 1 Hr
1F1	Heater	Total (fuel gas)	12.3	12.6	12.7	12.4
1F2	Heater	Total (fuel gas)	7.9	8.1	8.2	8.0
1BF1	Heater	Total (fuel gas)	16.5	17.0	17.1	16.8
31F1	Boiler	Total	14.6	14.9	14.7	14.7
		From fuel gas	8.7	9.1	8.8	8.8
		From fuel oil	5.9	5.9	5.9	5.9
31F2	Boiler	Total	14.4	15.3	14.7	14.9
		From fuel gas	10.7	11.5	11.0	11.1
		From fuel oil	3.8	3.8	3.8	3.8
3F2	Boilers	Total	Bad	Bad	Bad	Bad
A11	Stack	Total	4.8	4.8	4.9	4.7

LYTTON REFINERY SOURCE EMISSIONS MONITORING DATA for Opacity

			Last Hour Readings (%)			
Source	Source Description	Fuel source	Current Reading	- 0.25 Hr	- 0.5 Hr	- 1 Hr
3F2	Boilers	Fuel gas	43.0	44.7	44.2	44.5
A11	Stack	Fuel gas	41.6	43.7	42.9	42.7

Data for pdf generated at:

16-Nov-25 11:50:07