



**Monthly summary monitoring data**

Licence Details: Ampol Refineries (NSW) Pty Ltd, 2 Solander St, Kurnell, NSW, 2231, EPL # 837

EPA Point		Point 27, Yena Gap Effluent, Normal Operating Conditions										Date Last Data were Obtained	Reason for Missing Data	Publishing Date
Pollutant	Temperature	pH	Volumetric Flowrate	Oil and Grease	Phenols	Sulfide (un-ionised hydrogen sulfide)	Nitrogen (ammonia)	Total Suspended Solids	Biochemical Oxygen Demand	Monitoring Frequency Required by Licence				
Licence Limit (100%tile)	40	6.0 - 9.0	None		2.7	None	7.5	50	30					
Licence Limit (90%tile)		6.5 - 8.5		10										
Licence Limit (50%tile)					0.3			35	20					
Unit of Measure	°C		kl/day	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l					
Reporting Period	Month	Averaging Period	1 Hour Block	6 Minute Rolling	1 Day Block	Grab Sample	Grab Sample	Grab Sample	Grab Sample	Grab Sample	Grab Sample			
2024 - 2025 May	2-May 31-May 2024	No. Samples Collected	744	44640	31							12-Jun-24	No Missing Data	15-Jun-24
		Lowest	16.5	6.5	0									
		Highest	21.3	8.5	9824									
		Exceedance (yes/no)	No	No	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
2024 - 2025 Jun	1-Jun 30-Jun 2024	No. Samples Collected	720	43200	30							9-Jul-24	No Missing Data	15-Jul-24
		Lowest	13.2	6.5	0									
		Highest	18.3	8.5	9859									
		Exceedance (yes/no)	No	No	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
2024 - 2025 Jul	1-Jul 31-Jul 2024	No. Samples Collected	744	44640	31							6-Aug-24	No Missing Data	15-Aug-24
		Lowest	15.1	6.5	0									
		Highest	16.9	8.3	11489									
		Exceedance (yes/no)	No	No	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
2024 - 2025 Aug	1-Aug 31-Aug 2024	No. Samples Collected	744	44640	31							5-Sep-24	No Missing Data	15-Sep-24
		Lowest	16.0	6.5	0									
		Highest	18.7	7.0	11476									
		Exceedance (yes/no)	No	No	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
2024 - 2025 Sep	1-Sep 30-Sep 2024	No. Samples Collected	720	43200	30							8-Oct-24	No Missing Data	15-Oct-24
		Lowest	19.2	6.7	0									
		Highest	21.3	7.8	10531									
		Exceedance (yes/no)	No	No	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
2024 - 2025 Oct	1-Oct 31-Oct 2024	No. Samples Collected	744	44640	31							5-Nov-24	No Missing Data	15-Nov-24
		Lowest	20.3	6.5	0									
		Highest	22.0	7.2	10798									
		Exceedance (yes/no)	No	No	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
2024 - 2025 Nov	1-Nov 30-Nov 2024	No. Samples Collected	720	43200	30							9-Dec-24	No Missing Data	15-Dec-24
		Lowest	22.8	6.5	0									
		Highest	25.1	7.3	9449									
		Exceedance (yes/no)	No	No	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
2024 - 2025 Dec	1-Dec 31-Dec 2024	No. Samples Collected	744	44640	31							3-Jan-25	No Missing Data	15-Jan-25
		Lowest	23.5	6.5	0									
		Highest	27.0	7.6	9578									
		Exceedance (yes/no)	No	No	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
2024 - 2025 Jan	1-Jan 31-Jan 2025	No. Samples Collected	744	44640	31							5-Feb-25	No Missing Data	15-Feb-25
		Lowest	24.4	6.5	0									
		Highest	27.6	7.7	8929									
		Exceedance (yes/no)	No	No	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
2024 - 2025 Feb	1-Feb 29-Feb 2025	No. Samples Collected	672	40320	28							3-Mar-25	No Missing Data	14-Mar-25
		Lowest	25.1	6.9	0									
		Highest	26.4	7.6	6962									
		Exceedance (yes/no)	No	No	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
2024 - 2025 Mar	1-Mar 31-Mar 2025	No. Samples Collected	744	44640	31							7-Apr-25	No Missing Data	15-Apr-25
		Lowest	26.0	6.9	0									
		Highest	27.2	8.0	11125									
		Exceedance (yes/no)	No	No	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
2024 - 2025 Apr	1-Apr 1-May 2025	No. Samples Collected	720	43200	30							12-May-25	No Missing Data	15-May-25
		Lowest	21.8	6.5	0									
		Highest	24.5	7.5	11202									
		Exceedance (yes/no)	No	No	N/A	N/A	N/A	N/A	N/A	N/A	N/A			

Ampol Refineries (NSW) has prepared this information in good faith exercising all due care and attention, but no representation or warranty, express or implied is made as to the relevance, accuracy, completeness or fitness for purpose of this information in respect of any particular user's circumstances. Provision of this information does not constitute an opinion or interpretation by Ampol of the information and users of this information should satisfy themselves concerning its application to, and where necessary seek expert advice in respect of, their situation. Under no circumstances will Ampol be liable for any loss or damage however caused, resulting from your use of or access to, or inability to use or access, this information.



**Monthly summary monitoring data**

Licence Details: Ampol Refineries (NSW) Pty Ltd, 2 Solander St, Kurnell, NSW, 2231, EPL # 837

EPA Point	Point 27, Yena Gap Effluent, Wet Weather By-Pass Conditions			
Pollutant	Oil and Grease (Wet)	Phenols (Wet)	Total Suspended Solids (Wet)	Biochemical oxygen demand (Wet)
Licence Limit (100%tile)	70	5	100	350
Licence Limit (90%tile)				
Licence Limit (50%tile)				
Unit of Measure	mg/l	mg/l	mg/l	mg/l
Monitoring Frequency Required by Licence	Daily only during any discharge under bypass conditions of the biotreater wastewater treatment plant			

Reporting Period	Month	Averaging Period	Grab Sample	Grab Sample	Grab Sample	Grab Sample	Date Last Data were Obtained	Reason for Missing Data	Publishing Date
2024 - 2025 May	2-May 31-May 2024	No. Samples Collected	21	21	21	21	N/A	No Missing Data	15-Jun-24
		Lowest	<5	0.08	4	8			
		Highest	12	0.45	20	114			
		Exceedance (yes/no)	No	No	No	No			
2024 - 2025 Jun	1-Jun 30-Jun 2024	No. Samples Collected	28	28	28	27	9-Jul-24	No Missing Data	15-Jul-24
		Lowest	<5	<0.05	1	3			
		Highest	<10	0.31	17	59			
		Exceedance (yes/no)	No	No	No	No			
2024 - 2025 Jul	1-Jul 31-Jul 2024	No. Samples Collected	21	21	21	21	6-Aug-24	No Missing Data	15-Aug-24
		Lowest	<5	<0.05	4	3			
		Highest	16	0.45	10	30			
		Exceedance (yes/no)	No	No	No	No			
2024 - 2025 Aug	1-Aug 31-Aug 2024	No. Samples Collected	18	18	18	18	5-Sep-24	No Missing Data	15-Sep-24
		Lowest	<5	0.15	3	8			
		Highest	<5	0.29	10	24			
		Exceedance (yes/no)	No	No	No	No			
2024 - 2025 Sep	1-Sep 30-Sep 2024	No. Samples Collected	9	9	9	9	8-Oct-24	No Missing Data	15-Oct-24
		Lowest	<5	0.07	5	8			
		Highest	<5	0.15	34	74			
		Exceedance (yes/no)	No	No	No	No			
2024 - 2025 Oct	1-Oct 31-Oct 2024	No. Samples Collected	9	9	9	9	5-Nov-24	No Missing Data	15-Nov-24
		Lowest	<5	<0.05	6	17			
		Highest	<5	0.56	15	34			
		Exceedance (yes/no)	No	No	No	No			
2024 - 2025 Nov	1-Nov 30-Nov 2024	No. Samples Collected	8	8	8	8	9-Dec-24	No Missing Data	15-Dec-24
		Lowest	<5	0.14	13	<5			
		Highest	<5	0.27	19	88			
		Exceedance (yes/no)	No	No	No	No			
2024 - 2025 Dec	1-Dec 31-Dec 2024	No. Samples Collected	8	8	8	8	3-Jan-25	No Missing Data	15-Jan-25
		Lowest	<5	0.16	8	16			
		Highest	<5	0.29	16	36			
		Exceedance (yes/no)	No	No	No	No			
2024 - 2025 Jan	1-Jan 31-Jan 2025	No. Samples Collected	11	11	11	11	5-Feb-25	No Missing Data	15-Feb-25
		Lowest	<5	0.10	8	15			
		Highest	<5	0.17	23	42			
		Exceedance (yes/no)	No	No	No	No			
2024 - 2025 Feb	1-Feb 29-Feb 2025	No. Samples Collected	10	10	10	10	3-Mar-25	No Missing Data	14-Mar-25
		Lowest	<5	0.14	8	15			
		Highest	<5	0.25	16	32			
		Exceedance (yes/no)	No	No	No	No			
2024 - 2025 Mar	1-Mar 31-Mar 2025	No. Samples Collected	11	11	11	11	7-Apr-25	No Missing Data	15-Apr-25
		Lowest	<5	<0.05	6	12			
		Highest	<5	0.30	17	28			
		Exceedance (yes/no)	No	No	No	No			
2024 - 2025 Apr	1-Apr 1-May 2025	No. Samples Collected	14	14	14	14	12-May-25	No Missing Data	15-May-25
		Lowest	<5	0.06	<5	12			
		Highest	<5	0.20	17	38			
		Exceedance (yes/no)	No	No	No	No			

*Ampol Refineries (NSW) has prepared this information in good faith exercising all due care and attention, but no representation or warranty, express or implied is made as to the relevance, accuracy, completeness or fitness for purpose of this information in respect of any particular user's circumstances. Provision of this information does not constitute an opinion or interpretation by Ampol of the information and users of this information should satisfy themselves concerning its application to, and where necessary seek expert advice in respect of, their situation. Under no circumstances will Ampol be liable for any loss or damage however caused, resulting from your use of or access to, or inability to use or access, this information.*



**Monthly summary monitoring data**

Licence Details: Ampol Refineries (NSW) Pty Ltd, 2 Solander St, Kurnell, NSW, 2231, EPL # 837

EPA Point		Point 27, Yena Gap Effluent, Normal Operating Conditions											Date Last Data were Obtained	Reason for Missing Data	Publishing Date
Reporting Period	Month	Averaging Period	Grab Sample	Grab Sample	Grab Sample	Grab Sample	Grab Sample	Grab Sample	Grab Sample	Grab Sample	Grab Sample	Grab Sample			
		Pollutant	Arsenic	Ethyl Benzene	Lead	Naphthalene	Nickel	Phenanthrene	Benzene	Toluene	Polycyclic Aromatic Hydrocarbons	2,4-Dimethyl-phenol			
		Licence Limit (100%tile)	0.07	None	0.025	None	0.03	None	None	None	0.5	None			
		Licence Limit (90%tile)													
		Licence Limit (50%tile)									0.03				
		Unit of Measure	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l			
		Monitoring Frequency Required by Licence	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly	Monthly			
2024 - 2025	May	2-May 31-May 2024	No. Samples Collected	1	1	1	1	1	1	1	1	1	1	1	1
			Lowest	0.001	<0.005	<0.001	0.0129	0.002	0.0007	0.056	0.073	0.0136	0.0212		
			Highest	0.001	<0.005	<0.001	0.0129	0.002	0.0007	0.056	0.073	0.0136	0.0212		
			Exceedance (yes/no)	No	No	No	No	No	No	No	No	No	No		
2024 - 2025	Jun	1-Jun 30-Jun 2024	No. Samples Collected	1	1	1	1	1	1	1	1	1	1	1	1
			Lowest	<0.001	<0.005	<0.001	0.0326	<0.001	<0.0048	<0.005	<0.005	0.0326	0.0498		
			Highest	<0.001	<0.005	<0.001	0.0326	<0.001	<0.0048	<0.005	<0.005	0.0326	0.0498		
			Exceedance (yes/no)	No	No	No	No	No	No	No	No	No	No		
2024 - 2025	Jul	1-Jul 31-Jul 2024	No. Samples Collected	1	1	1	1	1	1	1	1	1	1	1	1
			Lowest	<0.001	0.005	<0.001	0.0071	<0.001	<0.0048	0.0790	0.3460	0.0071	0.0131		
			Highest	<0.001	0.005	<0.001	0.0071	<0.001	<0.0048	0.0790	0.3460	0.0071	0.0131		
			Exceedance (yes/no)	No	No	No	No	No	No	No	No	No	No		
2024 - 2025	Aug	1-Aug 31-Aug 2024	No. Samples Collected	1	1	1	1	1	1	1	1	1	1	1	1
			Lowest	0.001	<0.005	<0.001	0.0057	<0.001	<0.0002	0.147	0.720	0.0057	0.008		
			Highest	0.001	<0.005	<0.001	0.0057	<0.001	<0.0002	0.147	0.720	0.0057	0.008		
			Exceedance (yes/no)	No	No	No	No	No	No	No	No	No	No		
2024 - 2025	Sep	1-Sep 30-Sep 2024	No. Samples Collected	1	1	1	1	1	1	1	1	1	1	1	1
			Lowest	<0.001	<0.005	<0.001	0.0125	0.001	<0.0002	0.054	0.469	0.0125	0.0323		
			Highest	<0.001	<0.005	<0.001	0.0125	0.001	<0.0002	0.054	0.469	0.0125	0.0323		
			Exceedance (yes/no)	No	No	No	No	No	No	No	No	No	No		
2024 - 2025	Oct	1-Oct 31-Oct 2024	No. Samples Collected	1	1	1	1	1	1	1	1	1	1	1	1
			Lowest	0.001	<0.002	<0.001	<0.0002	<0.001	0.0002	<0.001	<0.002	<0.0002	<0.0002		
			Highest	0.001	<0.002	<0.001	<0.0002	<0.001	0.0002	<0.001	<0.002	<0.0002	<0.0002		
			Exceedance (yes/no)	No	No	No	No	No	No	No	No	No	No		
2024 - 2025	Nov	1-Nov 30-Nov 2024	No. Samples Collected	1	1	1	1	1	1	1	1	1	1	1	1
			Lowest	0.003	<0.002	<0.001	0	<0.001	<0.005	<0.001	<0.002	0.0086	0.0425		
			Highest	0.003	<0.002	<0.001	0	<0.001	<0.005	<0.001	<0.002	0.0086	0.0425		
			Exceedance (yes/no)	No	No	No	No	No	No	No	No	No	No		
2024 - 2025	Dec	1-Dec 31-Dec 2024	No. Samples Collected	1	1	1	1	1	1	1	1	1	1	1	1
			Lowest	0.001	<0.005	<0.001	0.0160	<0.001	<0.005	0.057	0.170	0.0160	0.0933		
			Highest	0.001	<0.005	<0.001	0.0160	<0.001	<0.005	0.057	0.170	0.0160	0.0933		
			Exceedance (yes/no)	No	No	No	No	No	No	No	No	No	No		
2024 - 2025	Jan	1-Jan 31-Jan 2025	No. Samples Collected	1	1	1	1	1	1	1	1	1	1	1	1
			Lowest	0.001	<0.002	<0.001	0.0011	<0.001	<0.0002	<0.001	<0.002	0.0011	0.0018		
			Highest	0.001	<0.002	<0.001	0.0011	<0.001	<0.0002	<0.001	<0.002	0.0011	0.0018		
			Exceedance (yes/no)	No	No	No	No	No	No	No	No	No	No		
2024 - 2025	Feb	1-Feb 29-Feb 2025	No. Samples Collected	1	1	1	1	1	1	1	1	1	1	1	1
			Lowest	0.002	<0.002	<0.001	<0.0002	<0.001	<0.0002	<0.001	<0.002	<0.0002	0.0140		
			Highest	0.002	<0.002	<0.001	<0.0002	<0.001	<0.0002	<0.001	<0.002	<0.0002	0.0140		
			Exceedance (yes/no)	No	No	No	No	No	No	No	No	No	No		
2024 - 2025	Mar	1-Mar 31-Mar 2025	No. Samples Collected	1	1	1	1	1	1	1	1	1	1	1	1
			Lowest	0.001	<0.002	<0.001	<0.0048	0.001	<0.0048	<0.001	<0.002	<0.0024	<0.0048		
			Highest	0.001	<0.002	<0.001	<0.0048	0.001	<0.0048	<0.001	<0.002	<0.0024	<0.0048		
			Exceedance (yes/no)	No	No	No	No	No	No	No	No	No	No		
2024 - 2025	Apr	1-Apr 1-May 2025	No. Samples Collected	1	1	1	1	1	1	1	1	1	1	1	1
			Lowest	0.002	<0.002	<0.001	<0.0048	0.001	<0.0048	<0.001	<0.002	<0.0024	<0.0048		
			Highest	0.002	<0.002	<0.001	<0.0048	0.001	<0.0048	<0.001	<0.002	<0.0024	<0.0048		
			Exceedance (yes/no)	No	No	No	No	No	No	No	No	No	No		

Ampol Refineries (NSW) has prepared this information in good faith exercising all due care and attention, but no representation or warranty, express or implied is made as to the relevance, accuracy, completeness or fitness for purpose of this information in respect of any particular user's circumstances. Provision of this information does not constitute an opinion or interpretation by Ampol of the information and users of this information should satisfy themselves concerning its application to, and where necessary seek expert advice in respect of, their situation. Under no circumstances will Ampol be liable for any loss or damage however caused, resulting from your use of or access to, or inability to use or access, this information.