

AC9729 - UNIVERSAL SCREW INJECTOR

Replacement Parts		
AccuProbe UV and AccuProbe II	Parts kit (sensor, filters and leak standard bottle)	69383
	Sensor and filter	69384
	Sensor filters (package of 5)	69385
	Leak standard bottle	69386
AccuProbe UV	A/C Adapter—Universal (US, EU, UK, AU and NZ Plugs) UL Listed, CE and GS approved. Adapter: GMEGA-033120FX with ferrite bead. Manufacturer PN: K3-NF-30-A(N)BKO	69375
	Battery cover and screw	69388
	Carrying case - blow molded with inserts	69387
AccuProbe II	Carrying pouch	69361

Troubleshooting Guide		
PROBLEM	CHECK	REPAIR OR REPLACE
No power	Check for weak or reversed batteries	Replace batteries
Stays in "warm up" mode	- Sensor not plugged into socket correctly - Sensor open/defective	- Make sure sensor is pushed all the way down into socket - Replace sensor
No detection	- Check sensor with leak standard bottle - Check if the filter is dirty or sensor opening is plugged	- Replace sensor - Replace filter or clean out opening
Slow recovery after detection	Check if filter is dirty or sensor opening is plugged	Replace filter or clean out opening
No beeping	Nothing	Press mute button (if equipped) to turn speaker back on

Product Cleaning Instructions: Remove surface dust by wiping with a dry cloth.

Partial list of detectable SNAP* listed refrigerants	
R-12 ALTERNATIVES	R-22 ALTERNATIVES
R-134a, R-1234yf, R-401A (MP-39), R-401B (MP-66), R-401C (MP-52), R-406A (GHG)	R-407C, R-410A, R-410B, R-507
R-414A (GHG-X4), R-414B (Hot Shot), R-416A (Frig C, FR-12)	R-113, R-13B & R-503 ALTERNATIVES
R-409A (FX-56), Freeze 12, Free Zone, GHG-X5, GHG-HP, IKON 12	R-403B, R-508A, R-508B
R-502, R-500 ALTERNATIVES	HC REFRIGERANTS (not SNAP approved)
R-402A&B, R-404A, R-407A, R-408A, R-411A&B, R-507	R-290, R-600A, R-170/R-290, R-600A/R-290
* SNAP (Significant New Alternatives Program) is EPA program for ozone depleting refrigerants for mobile and stationary A/C systems	

Item: AC9729

Description: UNIVERSAL SCREW INJECTOR

Notes: N/A

Figure No	Part Number	Description	No. Reqd	Warranty Code
-----------	-------------	-------------	----------	---------------