

Intertek
ANSI/ISEA Z358.1-2014
09.01.2016

Emergency Eyewash and Shower Equipment:

Element	Paragraph/ Test Description	Price/ Model	Samples Required
Emergency Showers (Plumbed and Self-Contained)	4.1, 4.2, 4.3, 4.4 Visual Inspection: Valve operation and accessibility, dispersion pattern, containment protection. Dimensional Inspection: Head height, clearance, enclosure area Flow Rate: GPM	\$700	1 complete unit
Eye Wash Units (Plumbed and Self-Contained)	5.1, 5.2, 5.3 Visual Inspection: Flush both eyes simultaneously, stream same height, valve actuation and accessibility, containment protection, ease of cover removal, no sharp projections, room for face and hands. Flow Rate: GPM	\$500	1 complete unit
Eye/ Face Wash Equipment (Plumbed and Self-Contained)	6.1, 6.2, 6.3 Visual Inspection: Flush both eyes simultaneously, stream same height, valve actuation and accessibility, containment protection, ease of cover removal, no sharp projections, room for face and hands. Flow Rate: GPM	\$500	1 complete unit
Combination Units	7.1, 7.2, 7.3, 8.2.2 Each component tested as separate entity.	Fee as above per unit	1 complete unit
Combination Units	7.1, 7.2, 7.3, 8.2.2 Each component tested simultaneously.	\$75	1 complete unit
Personal Wash Units	8.1 Non-injurious velocity, tepid flushing fluid, instructions and expiration date affixed to unit.	\$250	1 complete unit
Drench Hose	8.2.1, 8.2.2 Visual Inspection: Valve actuation and accessibility (including sections 5 and 6 as applicable). Flow Rate: GPM, non-injurious velocity	\$400	1 complete unit
Assembly Charge	(if applicable)	\$150	
Report		\$100	

*** NOTES: 1. The above test fees do not include the cost of any retests that may be required.**

2. SEI adds a 10% surcharge to all testing when invoiced to the participant.