

**LOAD CALCULATIONS FOR ROW-HOUSING – RULE 8-200(2) (DUPLEXES,
TRIPLEXES, QUADRUPLEXES, TOWNHOUSES AND SINGLE FAMILY DWELLINGS
WITH SECONDARY SUITE**

Date of Issue: October 5, 2022

Information Bulletin No: IB-EL 2014-01

REVISION: 03

The following bulletin provides guidance on the application of rules pertaining to the 2021 BC Electrical Code Regulation. The requirements of local municipal authorities having jurisdiction may vary. Installers should consult with local authorities having jurisdiction, prior to undertaking work, to determine their requirements.

Scope:

This Bulletin provides clarification on rule 8-200(2), the calculation of the minimum ampacity of **service or feeder** conductors supplying two or more dwelling units of row-housing and includes single dwellings with secondary suites. (Note: Where it is intended to incorporate a secondary suite in a single dwelling, installers are advised to consult with the local authority having jurisdiction for Building Code requirements.)

Code definitions related to Rule 8-200(2)

Single dwelling or Single Family Dwelling (SFD)– a dwelling unit consisting of a detached house, one unit of a row house, or one unit of a semi-detached, duplex, triplex or quadruplex house.

Dwelling unit – one or more rooms for the use of one or more persons as a housekeeping unit with cooking, eating, living, and sleeping facilities.

Row-housing – This is not defined in the BC Electrical Code nor the BC Building Code. The local authority having jurisdiction for the BC Building Code may have by-laws that provide a definition. Typical examples of row-housing include: Duplexes, Triplexes, Quadruplexes, Townhouses, and Single Family Dwellings with a Suite.

When calculating the minimum ampacity of a service or feeder conductors supplying two or more dwelling units of row housing, the code requires the use of a greater value from 8-200(1)(a) or (b), and application of the demands from 8-202(3)(a)(i) to (v) plus the requirements of Rule 8-202(3)(b) to (e).

For buildings where units are 80m² or more:

BC Safety Authority is now Technical Safety BC.

While we have changed our name, we remain committed to our vision of *Safe technical systems. Everywhere.*

www.technicalsaftybc.ca | toll-free 1 866 566 7233

- 24,000 W is the minimum allowed load used in the calculation.
- Where the calculated load exceeds **24,000 W**, the calculated load value must be used.

For buildings where units are less than 80m².

- **14,400 W** is the minimum allowed ampacity of the feeder or service.
- where the calculated load exceeds **14,400 W**, the calculated load value must be used.

In addition to the minimum conductor ampacity, the calculation determines the required rating of the busbar in a multi-gang meter base where one is used.

EXAMPLES RULE 8-200(2)

Note: The objective is to provide examples of how to combine multiple units of row housing to arrive at the minimum allowable ampacity of the main service or feeder. To simplify examples, the load calculation in accordance with 8-200(1) for the individual units is not shown.

Example 1:

A duplex under 80m² per unit. Service voltage- 120/240 volts. Each unit is calculated in accordance with Rule 8-200(1). The following method is also used for a SFD with a suite, a Triplex, a Quadruplex or Townhouses where the units are fed from a common service or feeder.

Each unit of a duplex is 75m², with typical loads equalling 13,125 W and a baseboard heat load of 4,000W. The result is a calculated total of 17,125 W. Rule 8-200(2) directs us to 8-200(1) where the calculated load in this example has been determined to be 17,125W/240V – 72A. This calculated value is greater than the minimum 60A for units that are less than 80m² from 8-200(1)(b)(ii). Therefore, this calculated value is used in the calculation.

Next, apply **demand factors** from 8-202(3)(a)(i) to (v) plus 8-202(3)(b)(d) & (e).

Calculated load= 17,125 W

Rule	Demand Application	Result
8-202(3)(a)	17,125 W – 4,000 W (heat)	= 13,125 W
8-202(3)(a)(i)	1 unit@100%	= 13,125 W
8-202(3)(a)(ii)	1 unit@ 65% (.65 X 13,125 W)	= 8,531 W

BC Safety Authority is now Technical Safety BC.

While we have changed our name, we remain committed to our vision of *Safe technical systems. Everywhere.*

8-202(3)(a) & (b)	Heat 2 @ 4,000 W	=	8,000 W
	Total	=	<u>29,656 W</u>

Service conductors shall have a minimum ampacity of $(29,656 \text{ W}/240\text{V}) = 124$ amps

Example 2:

A duplex over 80m² per unit. Service voltage = 120/240 volts Each unit is calculated in accordance with Rule 8-200(1). The following method is also used for a SFD with a suite, a triplex, a Quadruplex, or townhouses where the units are fed from a common service or feeder.

Each unit of a duplex is 85m² with 4,000 W of baseboard heat. Rule 8-200 2) directs us to 8-200 1) where the calculated load for this example is 17,125 W, $(17,125/240) = 71.35$ amps. This calculated value is less than the minimum 100A for units that are 80m² or greater from 8-200 1) b) ii). The minimum of 100A from 8-200 1) b) i) is to be used in the calculation.

Next, apply **demand factors** from 8-202 3) a) i) to v) plus 8-202 3) b), c), & d).

100A – 24,000 W

Rule	Demand Application		Result
8-202 3) b)	24,000W – 4,000W (heat)	=	20,000 W
<hr/>			
8-202 3) a) i)	1 unit@ 100%	=	20,000 W
8-202 3) a) ii)	1 unit @ 65% (.65 X 20,000 W)	=	13,000 W
8-202 3) a) & b)	Heat 2 @ 4,000 W	=	8,000 W
	Total	=	<u>41,000 W</u>

Service conductors shall have a minimum ampacity of $(41,000 \text{ W} / 240 \text{ V}) = 171$ amps

Example3:

A duplex with a calculated load over 100A per unit. Each unit is calculated in accordance with Rule 8-200 1). The following method is also used for a SFD with a suite, a triplex, a Quadruplex, or townhouses where the units are fed from a common service or feeder.

BC Safety Authority is now Technical Safety BC.

While we have changed our name, we remain committed to our vision of *Safe technical systems. Everywhere.*

Each unit of a duplex is 191 m² with 12,000 W of baseboard heat. Rule 8-200 2) directs us to 8-200 1) where a calculated load is determined to be 27,375 W per unit

Rule	Demand Application	Result
	Heat (individual unit)	= 12,000 W
62-118 3) a)	1 st 10,000 W @ 100%	= 10,000 W
62-118 3) b)	Balance 2000W @ 75%	= 1,500 W
	<u>Heat per unit</u>	= <u>11,500 W</u>
	Basic calculated load for each unit, excluding heat demand of 11,500 W	
8-200 2) a) & b)	(27,375 W – 11,500 W)	= 15,875 W
	<i>Note: see above for rule 62-116 calculation</i>	
8-202 3) a) i)	1 st unit @ 100%	= 15,875 W
8-202 3) a) ii)	2 nd unit @ 65% (.65 X 15, 875 W)	= 10,318 W
	<u>Subtotal (15,875 W + 10,318 W)</u>	= <u>26, 193 W</u>
8-202 3) b)	Total heating loads	= 24,000 W
62-118 3) a)	1 st 10,000 W @ 100%	= 10,000 W
62-118 3) b)	Balance 14,000 W @ 75%	= 10,500 W
	<u>Total calculated heating demand</u>	= <u>20,500 W</u>
<u>Total calculated demand</u>	(26,193 W + 20,500 W)	= <u>46, 693W</u>

Example 4:

A 10-unit town house complex fed from a main electrical room

A 10-unit townhouse complex with one service to a meter stack, each unit is 85m², with 4,000 W of baseboard heat. A house load of 11 X 175 W street lights, 6 X 120 V, 20 A vehicle charging receptacles, and 1,000 W of heat. Calculated load for each unit, including heat, is 17,125 W.

BC Safety Authority is now Technical Safety BC.

While we have changed our name, we remain committed to our vision of *Safe technical systems. Everywhere.*

The calculated load, 17,125 W = 72 amps @ 240 volts or 82.3 amps @ 208 volts, is less than 100 amp minimum, as per. 8-200 1) b) (over 80m2). Next, apply demand factors from 8-202 3) a) i) to v) plus 8-202 3) b), c) & d)

Rule	Demand Application	Results
8-200 2) a) & 1) b)	100 A X 240 V	= 24,000 W
8-200 2) & b)	24,000 W – 4,000 W heat	= 20,000 W
8-202 3) a) i)	1 unit @ 100%	= 20,000 W
8-202 3) a) ii)	2 units @ 65%	= 26,000 W
	2 units @ 40%	= 16,000 W
	5 units @ 25%	= 25,000 W
	<u>Subtotal</u>	= <u>87,000 W</u>

Rule 62-118 3)	Heat load = 10 X 4,000 W	= 40,000 W
	1 st 10,000 W @ 100%=	10,000 W
	Remainder 30,000 W @ 75%=	22,500 W
	Heat (subtotal)	= <u>32,500 W</u>

Rule	Demand Application	Result
House Loads		
8-202 3) e)	Lights = 11 X 175 W @ 75%	= 1,444 W
8-202 3) e)	Heat 1,000 W @ 75%	= 750 W
8-202 3) d)	Chargers 6 X 120 V X 20 A @ 100%	= 14,400W
	<u>Subtotal</u>	= <u>16,594 W</u>

BC Safety Authority is now Technical Safety BC.

While we have changed our name, we remain committed to our vision of *Safe technical systems. Everywhere.*

$$\begin{array}{rcl} 8-104 6) a) & \text{House Load deemed Continuous} & = \\ \underline{16,594 \text{ W}} & \text{therefore } 16,594 / .80 & = \underline{20,743 \text{ W}} \end{array}$$

Total demand

Units (from previous page)	=	87,000 W
Heat (from previous page)	=	32,500 W
House load	=	20,743 W
<u>Total</u>	=	<u>140,243 W</u>

The minimum ampacity of the service conductors is **584 A** (140,243 W / 240V).

Provincial Safety Manager

BC Safety Authority is now Technical Safety BC.

While we have changed our name, we remain committed to our vision of *Safe technical systems. Everywhere.*