

Analyte	Pebble Creek				Seaboard				South-Central / Lithia WTP				South-Central / Central WTP				Northwest / Lake Park WTP				Northwest / Fawn Ridge WTP			
	Quarter 1 January 2023	Quarter 2 April 2023	Quarter 3 July 2023	Quarter 4 October 2023	Quarter 1 January 2023	Quarter 2 April 2023	Quarter 3 July 2023	Quarter 4 October 2023	Quarter 1 July 2023	Quarter 2 October 2023	Quarter 3 January 2024	Quarter 4 April 2023	Quarter 1 July 2023	Quarter 2 October 2023	Quarter 3 January 2024	Quarter 4 April 2023	Quarter 1 July 2023	Quarter 2 October 2023	Quarter 3 January 2024	Quarter 4 April 2023	Quarter 1 July 2023	Quarter 2 October 2023	Quarter 3 January 2024	Quarter 4 April 2023
PFOS	ND	5.1	7.1	ND	ND	5.2	7.1	6.8	ND	ND	ND		5.4	4.4	4.4		ND	ND	ND		ND	ND	ND	
PFOA	ND	ND	4.3	ND	ND	ND	4.0	4.5	ND	ND	ND		ND	ND	ND		ND	ND	ND		ND	ND	ND	
HFPO-DA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		ND	ND	ND		ND	ND	ND		ND	ND	ND	
PFBS	4.5	4.8	6.6	ND	5.2	4.9	6.0	6.4	ND	ND	ND		5.0	4.2	3.8		ND	ND	ND		ND	ND	ND	
PFNA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		ND	ND	ND		ND	ND	ND		ND	ND	ND	
PFHxS	ND	4.0	3.6	ND	ND	4.2	3.2	4.0	ND	ND	ND		ND	ND	ND		ND	ND	ND		ND	ND	ND	
Hazard Index Calculation	0.002	0.447	0.403	0	0.003	0.47	0.36	0.45	0	0	0		0.003	0.002	0.002		0	0	0		0	0	0	

- Results are in parts per trillion.
- ND means no detectable levels found.
- [PFOA and PFOS EPA proposed MCLs are 4.0 ppt](#)
- EPA's Hazard Index is a calculation used to determine combined levels of four PFAS. [The EPA proposed Hazard Index Maximum Contaminant Level is 1.](#) The individual health-based values for each substance used in the calculation are:
 - PFBS - 2,000 parts per trillion
 - PFHxS - 9 parts per trillion
 - PFNA - 10 parts per trillion
 - HFPO-DA (Gen X) - 10 parts per trillion