

| Analyte                  | Pebble Creek              |                         |                        |                           | Seaboard                  |                         |                        |                           | South-Central / Lithia WTP |                           |                           |                         | South-Central / Central WTP |                           |                           |                         | Northwest / Lake Park WTP |                           |                           |                         | Northwest / Fawn Ridge WTP |                           |                           |                         |
|--------------------------|---------------------------|-------------------------|------------------------|---------------------------|---------------------------|-------------------------|------------------------|---------------------------|----------------------------|---------------------------|---------------------------|-------------------------|-----------------------------|---------------------------|---------------------------|-------------------------|---------------------------|---------------------------|---------------------------|-------------------------|----------------------------|---------------------------|---------------------------|-------------------------|
|                          | Quarter 1<br>January 2023 | Quarter 2<br>April 2023 | Quarter 3<br>July 2023 | Quarter 4<br>October 2023 | Quarter 1<br>January 2023 | Quarter 2<br>April 2023 | Quarter 3<br>July 2023 | Quarter 4<br>October 2023 | Quarter 1<br>July 2023     | Quarter 2<br>October 2023 | Quarter 3<br>January 2024 | Quarter 4<br>April 2024 | Quarter 1<br>July 2023      | Quarter 2<br>October 2023 | Quarter 3<br>January 2024 | Quarter 4<br>April 2024 | Quarter 1<br>July 2023    | Quarter 2<br>October 2023 | Quarter 3<br>January 2024 | Quarter 4<br>April 2024 | Quarter 1<br>July 2023     | Quarter 2<br>October 2023 | Quarter 3<br>January 2024 | Quarter 4<br>April 2024 |
| PFOS                     | ND                        | 5.1                     | 7.1                    | ND                        | ND                        | 5.2                     | 7.1                    | 6.8                       | ND                         | ND                        | ND                        | ND                      | 5.4                         | 4.4                       | 4.4                       | 4.0                     | ND                        | ND                        | ND                        | ND                      | ND                         | ND                        | ND                        | ND                      |
| PFOA                     | ND                        | ND                      | 4.3                    | ND                        | ND                        | ND                      | 4.0                    | 4.5                       | ND                         | ND                        | ND                        | ND                      | ND                          | ND                        | ND                        | ND                      | ND                        | ND                        | ND                        | ND                      | ND                         | ND                        | ND                        | ND                      |
| HFPO-DA                  | ND                        | ND                      | ND                     | ND                        | ND                        | ND                      | ND                     | ND                        | ND                         | ND                        | ND                        | ND                      | ND                          | ND                        | ND                        | ND                      | ND                        | ND                        | ND                        | ND                      | ND                         | ND                        | ND                        | ND                      |
| PFBS                     | 4.5                       | 4.8                     | 6.6                    | ND                        | 5.2                       | 4.9                     | 6.0                    | 6.4                       | ND                         | ND                        | ND                        | ND                      | 5.0                         | 4.2                       | 3.8                       | 4.5                     | ND                        | ND                        | ND                        | ND                      | ND                         | ND                        | ND                        | ND                      |
| PFNA                     | ND                        | ND                      | ND                     | ND                        | ND                        | ND                      | ND                     | ND                        | ND                         | ND                        | ND                        | ND                      | ND                          | ND                        | ND                        | ND                      | ND                        | ND                        | ND                        | ND                      | ND                         | ND                        | ND                        | ND                      |
| PFHxS                    | ND                        | 4.0                     | 3.6                    | ND                        | ND                        | 4.2                     | 3.2                    | 4.0                       | ND                         | ND                        | ND                        | ND                      | ND                          | ND                        | ND                        | ND                      | ND                        | ND                        | ND                        | ND                      | ND                         | ND                        | ND                        | ND                      |
| Hazard Index Calculation | 0.002                     | 0.447                   | 0.403                  | 0                         | 0.003                     | 0.47                    | 0.36                   | 0.45                      | 0                          | 0                         | 0                         | 0                       | 0.003                       | 0.002                     | 0.002                     | 0.002                   | 0                         | 0                         | 0                         | 0                       | 0                          | 0                         | 0                         | 0                       |

- Results are in parts per trillion (ppt)
- ND means no detectable levels found.
- [PFOA and PFOS EPA future MCLs are 4.0 ppt as running annual average](#)
- [PFHxS, PFNA, and HFPO-DA \(Gen X\) future MCLs are 10 ppt as running annual average](#)
- EPA's Hazard Index is a calculation used to determine combined levels of four PFAS. [The EPA future Hazard Index Maximum Contaminant Level is 1.](#) The individual health-based values for each substance used in the calculation are:
  - PFBS - 2,000 ppt
  - PFHxS - 10 ppt
  - PFNA - 10 ppt
  - HFPO-DA (Gen X) - 10 ppt